

ELBERT COUNTY DEPARTMENT OF HEALTH AND HUMAN SERVICES POBOX924 75 Ute Avenue Kiowa, CO 80117 P (303) 621-3149 / F (303) 621-0122

Jerri Spear
Director

June 26, 2018

Wayne Connell PO Box 2434 Parker, CO 80138

Re: 37300 Stillwater St.

Assessor Parcel ID# 7527202003

New Septic Permit #2018-999

Dear Mr. Connell,

This department received an engineered design for the installation of a septic system located at the above address. The permit is approved with the following stipulations;

- 1. Install per your engineer; Rocky Mountain Group dated February 15, 2018, Job #159927. System designed for FOUR (4) bedrooms.
- 2. The septic system must NOT be installed within any flood plains. Provide documentation of flood plains on site.
- 3. Installer must be licensed to install septic systems in Elbert County, be approved by engineer and be familiar with installing septic systems. Installer and builder responsible for placement of system within property boundaries and in area of soils tests.
- 4. All electrical installations must be performed by licensed electrician and be inspected. All electrical boxes must be mounted properly and off the ground at the septic tank(s).
- 5. Engineer must perform their required inspections. Installer must contact this department with any installation problems and for required inspections. Installer must also provide "record drawing" of completed system to this department.
- 6. Enginger must provide final signoff and acceptance of the installation to this department.

If you or your installer should have any question, please contact this department.

Gary L. Hartzell

EHS/REHS

Elbert County Department of Public Health and Human Services cc: Elbert County Building Department